

# THERMAL SIMULATION REPORT

Report Number:	TCL2019-CUBO-001
Prepared For:	Cubo Rooflights 2-4 Fairgreen Terrace Bray Wicklow A98 N738
Window System Identifier:	Flush Glaze (Double Glazed)
Frame Identifier:	CUBO 160
Glazing System:	6-20-6 6mm Float, 6mm Guardian Climaguard A+ 90% Argon Fill
Spacer Bar:	Thermoseal Thermobar
Notes:	Result is obtained assuming glass is in vertical orientation as laid down in both UK and Ireland Building Regulations.

## Results

Thermal Transmittance Based on Internal Developed Area	1.2	W/(m <sup>2</sup> K)
-----------------------------------------------------------	-----	----------------------

(Rooflight Configuration 1230mm wide x 1480mm high as per the requirements of EN 14351)

Report Prepared by Dr Gary Morgan  
Therm Consulting Ltd.

Signed: *G Morgan*

Date: 25<sup>th</sup> November 2019

The simulations in this report were performed using Win Iso 2D Pro version 7.93, strictly in accordance with the requirements of EN ISO 10077-2:2017.

The rooflight U value was calculated in accordance with the requirements of BS EN ISO 10077-1:2017.

The simulation files and spreadsheets generated are attached to this report as appendices.



**BFRC Certified  
Simulator 016**